



Paul W. Ferriero, PE, PP, CME, LEED AP, CFM
Robert C. Brightly, PE, PP, CME

Steven B. Bolio, PE, CME
Joseph P. Byrne, PE
Mark S. Denisiuk, PE, CME, LEED AP
Mark W. Kataryniak, PE, PTOE
Joseph S. Kosinski, PG, CFM, LEED AP
C. Richard Quamme, PE, CME
Jess H. Symonds, PE

February 6, 2023

Lisa Smith, Secretary
Mendham Borough Joint Land Use Board
2 West Main Street
Mendham, New Jersey 07945

Re: V-Fee Mendham Apartments, LLC Site Plan Application
Block 801, Lot 20
84-90 East Main Street
FEI Project No. 22MB212

Dear Lisa:

The above referenced application requests preliminary and final site plan and variance approval for the construction of a 75 unit inclusionary apartment building at the rear of the Kings Shopping Center on lot 20 in block 801. The project also includes an auto sales and service facility and indoor vehicle storage. The following documents have been submitted in support of the application:

1. Transmittal letter, dated January 31, 2023, from Dereck W. Orth, Esq.
2. Transmittal letter, dated January 13, 2023, from John P. Inglesino, Esq.
3. Land Development Application, dated September 19, 2022, prepared by Thomas Maoli
4. Certificate of Paid Taxes, dated December 8, 2022
5. Site Inspection form, dated September 19, 2022, prepared by Thomas Maoli
6. Checklist
7. Traffic Impact Study, dated October 20, 2022, prepared by John R. Corak, PE and Matthew J. Seckler, PE
8. Ecological Impact Statement, dated October 20, 2022, prepared by Chuck D. Olivo, PE
9. Stormwater Management Report, dated October 20, 2022, prepared by Chuck D. Olivo, PE
10. Property Survey, dated September 16, 2022, prepared by Thomas F. Miller, PLS
11. Architectural Plans, consisting of 11 sheets dated October 24, 2022, prepared by Dean Marchetto, AIA, PP
12. Site Plans, consisting of 28 sheets revised through January 25, 2023, prepared by Matthew Seckler, PE
13. Sewer Connection Application, dated December 12, 2022

• • •

■ 180 Main Street • P.O. Box 571 • Chester, NJ 07930 • 908-879-6209 • Fax: 908-879-6597
□ 17 Model Avenue • Hopewell, NJ 08525 • 609-466-0002 • Fax: 609-466-2008
mail@FerrieroEngineering.com

Re: V-Fee Mendham Apartments, LLC Site Plan Application
Block 801, Lot 20
84-90 East Main Street
FEI Project No. 22MB212

14. Morris County Planning Board Application, dated December 12, 2022
15. Property Owner's List, dated December 12, 2022
16. Planning Report, dated November 10, 2022, prepared by Philip Abramson, AICP/PP and Golda Speyer, AICP/PP
17. Flood Hazard Area Study, dated May, 2021, prepared by Clay H. Emerson, PE
18. Utility Service Letters
19. Tax map

A review of the above documents results in the following comments relative to the completeness of the application:

1. Jurisdictional Questions – The transmittal letter from the applicant's attorney states that these issues have been "resolved", however there has been no such confirmation by the Board attorney.
 - a. The site includes a cellular communications tower that was approved as part of a use variance by the prior Board of Adjustment. The Board Attorney should opine if the current application needs to be heard by the Land Use Board acting as a Board of Adjustment because of the prior Board of Adjustment approval.
 - b. The architectural plans identify one of the buildings as a "Premium Parking and Automobile Service Building. The project description in the Planning Report indicates that this is an automobile sales and service facility as well as area for "climate-controlled automobile storage." This issue is deferred to the Board Attorney and Planner, however it appears that a use variance may be required.
2. Checklist Item 24 – Approval signature lines – The plans have been corrected to address the previous error in the signature block however no revision date has been added to the plan. Whenever plan changes are made, a revision date is required. It is recommended that when the plans are submitted to the Board for review and hearing that full sets be revised to include a revision date for this change. All sheets should bear the same revision date.
3. Checklist Item 41 – Signage plan – The site plan indicates that the existing free standing sign will be "repurposed". Details are required. The applicant has requested that a waiver from submitted the plan until the first hearing on the application. This office has no objection subject to the information being submitted at least 14 days in advance of any hearing.
4. Checklist Item 46 – Drainage within 200' – All drainage within 200' is not shown. This office has no objection to a waiver for completeness, however additional information may be required based on the technical review.
5. Checklist Item 55 – Cost estimate for public improvements – No estimate has been provided. The applicant should confirm that all improvements will be privately owned, operated and maintained.

Ferriero Engineering, Inc.

February 6, 2023

Page 3

Re: V-Fee Mendham Apartments, LLC Site Plan Application

Block 801, Lot 20


84-90 East Main Street

FEI Project No. 22MB212

6. Checklist Item 57 – Utility service letters – The utility service letters provided indicate that the utilities have service to the property. They do not indicate whether or not the utilities have adequate capacity for that service. It should be noted that any costs associated utility upgrades required to provide service to the facility will be responsibility of the developer.

Subject to the Board granting the completeness waivers above, the application may be deemed complete.

Very truly yours,



Paul W. Ferriero, PE, CME

Borough Engineer

cc: Board members

Thomas Germinario, Esq.

Jessica Caldwell, PP/AICP